

**Imperial County
Workforce & Economic Development**

**County of Imperial
Palo Verde County Water District Water Well Replacement Project, Phase II
Project, No. ICCED-015
CDBG Grant #18-CDBG-12925**

ADDENDUM NO. 1

May 24, 2023

This ADDENDUM is hereby made part of the Contract Documents and specifications to the same extent as if originally included therein, and shall be signed by the Bidder and included with the proposal.

Question No. 1: Is direct mud rotary ok or is dual rotary only method?

Answer No. 1: Based on the existing site conditions, we do not feel that direct mud rotary drilling would be applicable for the new well. As such, we would not approve of the direct mud rotary drilling, and only allow dual rotary drilling.

**ADDENDUM NO. 1
ACCEPTANCE OF NOTICE**

Please acknowledge receipt of this Addendum No. 1 consisting of 2 pages, by signing and returning a copy of this Acceptance of Notice. Each bidder must acknowledge receipt of this addendum in the noted space below and on the signature page of the Bid Form. Include a copy of this signed Acceptance of Notice with your Bid Proposal Package. It is the Contractor's responsibility to notify its sub-contractors about changes based on addendums.

By: 
Jade Padilla
Program Manager

Date: May 24, 2023

ACCEPTANCE OF NOTICE

Receipt of the ADDENDUM No. 1 is hereby acknowledged by

Company Name

Date

By: _____
Print Name & Title

Signature